

Travis County MUD #10
Water Usage Report
August 2011

Total Residential Averages

	Oct-10	Nov-10	Dec-10	Jan-11	Feb-11	Mar-11	Apr-11	May-11	Jun-11	Jul-11	Aug-11	Year-to-Date
Raw Water (Meter)	2,467,000	1,807,000	1,525,000	1,502,000	1,760,000	1,883,000	3,642,000	2,369,000	3,791,000	4,060,000	2,821,000	27,627,000
Gallons Sold	-2,168,000	-1,753,000	-1,478,000	-1,270,000	-1,426,000	-1,657,000	-2,339,000	-2,149,000	-3,490,000	-3,690,000	-2,714,000	-24,134,000
Plant use (Meter)	-1,100	-1,100	-1,100	-10,000	-10,000	-10,000	-10,000	-10,000	-10,000	-10,000	-5,000	-5,000
Back Wash Water (Meter)	-10,000	-1,000	-1,000	-25,000	-25,000	-25,000	-10,000	-10,000	-10,000	-10,000	-5,000	-5,000
Flushing/Dumped/Leaks	-10,000	-500	-500	-15,000	-15,000	-15,000	-250,000	-1,500	-1,500	-1,500	-500	-500
Installed into new Tank/GST							-406,000					
GST							-188,000					
New Section/Contractor	0											
Total Water Loss	277,900	51,400	44,400	182,000	284,000	176,000	439,000	198,500	279,500	348,500	96,500	96,500
Water Loss Percentage	11%	3%	3%	12%	16%	9%	12%	8%	7%	9%	3%	3%
# Residential Connections	133	133	134	134	134	134	135	135	135	135	135	135
Total Gallons Sold	2,168,000	1,753,000	1,478,000	1,270,000	1,426,000	1,657,000	2,339,000	2,149,000	3,490,000	3,690,000	2,714,000	24,134,000
WOLT - POA	-118,000	-85,000	-98,000	-165,000	-65,000	-34,000	-118,000	-93,000	-65,000	-65,000	-69,000	-975,000
District Irr Meter L/S#2	-5,000	-4,000	-5,000	-2,000	-2,000	0	0	0	0	0	0	-18,000
Irrigation Meters	-459,000	-475,000	-384,000	-371,000	-469,000	-775,000	-735,000	-510,000	-499,000	-499,000	-457,000	-5,633,000
Total Residential Gallons	1,586,000	1,189,000	991,000	732,000	890,000	848,000	1,486,000	1,546,000	2,926,000	3,126,000	2,188,000	21,888,000
Average Per Connection	11,925	8,940	7,396	5,463	6,642	6,328	11,007	11,452	21,674	23,156	16,207	16,207

Total District Water Loss Report

	Oct-10	Nov-10	Dec-10	Jan-11	Feb-11	Mar-11	Apr-11	May-11	Jun-11	Jul-11	Aug-11	Year-to-Date
Raw Water (Meter)	2,467,000	1,807,000	1,525,000	1,502,000	1,760,000	1,883,000	3,642,000	2,369,000	3,791,000	4,060,000	2,821,000	27,627,000
Gallons Sold	-2,168,000	-1,753,000	-1,478,000	-1,270,000	-1,426,000	-1,657,000	-2,339,000	-2,149,000	-3,490,000	-3,690,000	-2,714,000	-24,134,000
Plant use (Meter)	-1,100	-1,100	-1,100	-10,000	-10,000	-10,000	-10,000	-10,000	-10,000	-10,000	-5,000	-5,000
Back Wash Water (Meter)	-10,000	-1,000	-1,000	-25,000	-25,000	-25,000	-10,000	-10,000	-10,000	-10,000	-5,000	-5,000
Flushing/Dumped (Meter)	-10,000	-500	-500	-15,000	-15,000	-15,000	-250,000	-1,500	-1,500	-1,500	-500	-500
Installed into new Tank							-406,000					
GST							-188,000					
New Section/Contractor	0											
Total Water Loss	277,900	51,400	44,400	182,000	284,000	176,000	439,000	198,500	279,500	348,500	96,500	96,500
Water Loss Percentage	11%	3%	3%	12%	16%	9%	12%	8%	7%	9%	3%	3%
# Active Connections	140	140	141	141	141	141	142	142	142	142	142	142
Total Gallons Sold	2,168,000	1,753,000	1,478,000	1,270,000	1,426,000	1,657,000	2,339,000	2,149,000	3,490,000	3,690,000	2,714,000	24,134,000
Average Per Connection	15,486	12,521	10,482	9,007	10,113	11,752	16,472	15,134	24,577	25,986	19,113	19,113

**NOTE - Feb 2011 Raw Water Line Freezed Damage

**NOTE - Mar 2011 New Meter (WTP) Installed.

***NOTE - Apr 2011 - 94K gallon tank flushed and refilled; other tanks topped off due to fire danger.